



CRH Series Bells ANM-001 & ANM-002

90dB Rating

Product codes ANM-001 & ANM-002 have been tested and “Deemed to Satisfy Provision, Section G – Ancillary Provisions, Part G1.2- Refrigerated Chambers, Strong Rooms and Vaults”- of the Australian Building Codes Board in relation to the following section:

G1.2 (a) A refrigerated or cooling chamber, strong room or vault which is of sufficient size for a person to enter must have:

(iv) an alarm that is

- a. located outside but controllable only from within the chamber, strong room or vault; and***
- b. able to achieve a sound pressure level outside the chamber, strong room or vault of 90dB(A) when measured 3m from the sounding device***

Both products ANM-001 & ANM-002 achieved a sound level of 95dB from a distance of 3m