



EcoGlide & Fermod
Testing Report for manually opening doors & exits.

Products Codes CRH-SSELHK Series & Fermod F420 & F430 Series Latch sets have been tested and “Deemed to Satisfy” Provision, D2.19 (iii) (B) “Doorways and doors”- of the Australian Building Codes Board in relation to the following section:

D2.19 (iii) (b)

The door is able to be opened manually under a force of not more than 110 N.

The following Parts were tested by in a controlled test environment achieving the results below.

Product Part Number	Product Description	Action	Result in Newtons for manual opening
CRH-SSELHK-75	External Lever Handle	Sliding	15 N (1.5KG)
CRH-SSELHK-100	External Lever Handle	Sliding	15 N (1.5KG)
CRH-SSELHK-150	External Lever Handle	Sliding	15 N (1.5KG)
CRH-SSELHK-200	External Lever Handle	Sliding	15 N (1.5KG)
CRH-SKA-37	Internal Lever Handle	Sliding	64 N (6.5KG)
F420	Latch Set	Push/Pull	49 N (5KG)
F430	Latch Set	Push/Pull	49 N (5KG)